



Drinking Water Quality and Compliance

for Village of Kenaston 2025 Annual Notice to Consumers

The Water Security Agency (WSA) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the Village of Kenaston water quality and sample submission compliance record for the January 1, 2025 to December 31, 2025 time period. This report was completed on May 19, 2026. Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	24	24	0

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	.82 - 1.57	.60 - 1.17	24	24	100

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	.34 – 1.32	365	0

A minimum of 0.1 milligrams per liter (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0	.22 - .89	0	0.89	365	365

Since December 2024, the permit to operate has required continuous turbidity monitoring of RO permeate (limit 0.1 NTU) or that strictly groundwater be used as a water source. Council is currently discussing the matter and working toward a solution.

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for WSA's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium. The last sample for Chemical Health analysis was submitted on **August 26, 2024**. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	0.010		0.0003	0	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	1.0		.0028	0	
Boron		5.0	0.2	0	
Cadmium	0.005		<0.15	0	
Chromium	0.05		<0.19	0	
Fluoride (avg*)	1.5		0.17	0	
Lead	0.01		< 0.0007	0	
Nitrate (avg.*)	45.0		0.5	0	
Selenium	0.01		<0.00113	0	
Uranium	0.02		0.0124	0	

Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for HAAs and THMs. Waterworks using groundwater sources beyond the influence of surface water do not need to report HAAs and THMs since sampling/analysis will not likely have been performed.

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)Required	# Samples Submitted	# Samples
Alkalinity	500	312	1	1
Bicarbonate	No Objective	381	1	1
Calcium	No Objective	94	1	1
Carbonate	No Objective	0	1	1
Chloride	250	11.7	1	1
Conductivity	No Objective	957	1	1
Hardness	800	449	1	1
Magnesium	200	52	1	1
pH	No Objective	7.7	1	1
Sodium	300	53	1	1
Sulphate	500	223.5	1	1
Total dissolved Solids	1500	820	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in 2024 and submitted on **August 26, 2024**. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical analysis.

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Village of Kenaston
Box 129, Kenaston, SK S0G 2N0
Telephone Number 252-2211